

NPDES 24hr Non-Compliance Report - Call Summary

Call Received By

Jason Rodriguez

Date of Call

3/3/2016

Time of Call

2:10 PM

NonComp Date

3/3/2016

Sector

Muni

[Print Current Form](#)

[Mail Today's Report](#)

[Open Query](#)

Caller Name

David Phundy

Caller Phone #

208-290-8266

Facility Name

Sandpoint, City of

Permit ID

ID0024350

NonCompliance Type

Effluent Limit Violation

Violation Description

Chlorine exceedance for approx. 30 min. recorded at .34 limit is .1

Comments

Form ID

1138

Entry Qtr

2016 Q1

Entry Date

3/4/2016